

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:56 am

PWS ID: UTAH09022 **Name:** TICABOO SPECIAL SERVICE DISTRICT
Legal Contact: TICABOO TOWN **Rating:** Approved
CHIP SHORTREED **Rating Date:** 04/09/1996
Address: BOX 2111 TICABOO **Activity Status:** Active
LAKE POWELL, UT 84533
Phone Number: 435-788-2180
City Served (Area):
County: GARFIELD COUNTY
System Type: Community **Last Inv Update:** 07/06/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 12/16/2009 **Total Dsgn Cap:**
Population: 60 **Surveyor:** JOHN GALLIS **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	SHORTREED, CHIP		435-788-8343	435-788-2020	CHIPSHORTREED@MSN.C

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	22
			22 Total Svc Connections

Storage

Total Storage: 500,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	TANK #1	Ground	500,000 GAL	Concrete		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1	Active	WL	5	150 GPM	150 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL #2	Active	WL		47 GPM	70 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.